

Certificate of Compliance

Certificate Number 20091118-EX6296
Report Reference 2009 November 18
Issue Date 2009 November 18

Page 3 of 3



**Underwriters
Laboratories Inc.**

This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Type III - Discharge devices that deliver foam directly onto the liquid surface at an angle above the horizontal. Examples include hand-held nozzles or monitors.

Unless otherwise stated in the individual Listings, the type of discharge outlet Listed with a foam is Type III.

Foam concentrates investigated with Listed sprinklers and fixed spray foam nozzles are intended to be installed in accordance with the applicable NFPA Standard, but in no case is the protected area intended to exceed sq. m.

Issued by:

Mona Couloute

Handwritten signature of Mona Couloute in black ink.

Reviewed by:

Monica Westphal

Handwritten signature of Monica Westphal in black ink.